

Handbook Series on Fire Safety

# Hospital Buildings

A basic guide for Fire Prevention, Life Safety & Fire Protection requirements for Hospital Buildings

HOSPITAL



**GUJARAT  
INSTITUTE OF  
DISASTER  
MANAGEMENT**  
BUILDING RESILIENCE



Directorate of State Fire Prevention Services,  
Government of Gujarat



Handbook Series on Fire Safety

# Hospital Buildings

A basic guide for Fire Prevention, Life Safety & Fire Protection requirements for Hospital Buildings

HOSPITAL



 **GUJARAT  
INSTITUTE OF  
DISASTER  
MANAGEMENT**  
BUILDING RESILIENCE



**Directorate of State Fire Prevention Services,  
Government of Gujarat**

## Handbook Series on Fire Safety


**Hospital Buildings:** A basic guide for Fire Prevention, Life Safety & Fire Protection requirements for the Hospital Buildings

**Published by**

**Gujarat Institute of Disaster Management**

**Gandhinagar - 382007**

**January 2022**



**Disclaimer:** This document is prepared to offer basic information on fire safety requirements for hospital buildings. However, this document does not replace the provisions mandated by GFP&LSM Act, 2013 or GFP&LSM Rules, 2014 or GFP&LSM Regulations or CGDCR or any other relevant Indian Standard(s)/ Code(s). Compliance with this handbook shall not be construed as eliminating or reducing the necessity for other provisions for safety of persons using a building or structure under hospital occupancy conditions.

## Message



Fire is a serious threat to the individual and property of any organization. A fire can pose an even greater threat to the life and health of individuals in hospital buildings. Because of their physical condition or medical status, many people in hospitals are not able to leave their beds. Further, hospitals contain ample oxygen supplies, volatile chemicals and other drugs that can spread fires and produce poisonous fumes into the air.

Health facilities are critical in responding to emergencies and disasters. They are among the frontline agencies that required to remain prepared for any hazardous event and first one to come in response action with other frontline agencies immediately as soon as the hazardous event strikes. And for this reason, it is very essential to ensure that the health facilities remain structurally safe and functional all the time. While the pandemic COVID 19 is still a major concern, the recent incidents of fire in hospitals stressed on the need for necessary preventive, mitigation and preparedness measures to be taken by health facilities to avert or minimize the impacts of any such fire hazard incidents.

The objective of preparing this document is to enhance the knowledge of all the stakeholders directly related to health care activities and engineers / architects on the basic fire safety measures to be implemented in hospital buildings/ premises. The document is divided in two parts i.e. Part A and Part B. Part A of the document focuses on basic understanding of fire safety concepts. Part B of the document consists of Fire Prevention, Life Safety and Fire Protection measures that engineers / architects need to considered in hospital buildings/ premises.

I am happy to acknowledge the support and cooperation extended by Mr. Snehanshu Choudhari for his contribution in drafting and Mr Paresh Vyas, Mr K K Bishnoi and Mr. Abhay Purandare, for patiently reading the various drafts, and offering constructive criticism, guidance and suggestions.

Finally, the efforts made by GIDM team especially, Mr. Nisarg Dave, Mr. Piyush Ramteke, Mr. Himalay Kotadiya and Ms. Shilpa Boricha for coming up with this handbook are highly appreciated. I hope this handbook will benefit all the stakeholders immensely. Further, I am sure that concerted efforts in this direction would help in building and creating a culture of fire prevention, life safety and fire protection which in turn would lead to a resilient society and the nation.



**(P K Taneja)**  
**Director General, GIDM**

**January, 2022**  
**Gandhinagar**

# Part - A

## How Fire Starts?

The three things, a fire needs to start are heat, fuel and oxygen. These three elements work together to start a fire. Fuel is the first element in the fire triangle. The fire will need a fuel source in order to continue to burn. The fuels readily available in hospital premises are surgical clothing, cotton waste, sanitizers, electrical equipments, laboratory chemicals, cooking oils etc. Heat is the second essential element that a fire needs. A fire can't even start or spread unless there's a significant amount of heat involved. That's why in majority of fires water is applied to cool the fire source. Commonly available heat sources in the hospitals are matches, gas stoves, electrical heating equipment etc. Finally, the third thing that is needed is oxygen. Oxygen is in the air all around us. So all the three things when they come together they cause fire.



*Figure 1: Fire Triangle*

If we need all of these things for a fire to burn, how do you put a fire out? You only need to take away one of these three things, and the fire will go out.

## What are the types of fire?

According to IS 15683: 2018, there are five classes of fires, namely:

- **Class A fire:** Fires involving solid combustible materials of organic nature such as combustible clothing, bed sheets, curtains, paper, plastics, etc.
- **Class B fire:** Fires involving flammable liquids e.g. sanitizers, diesel, petrol, laboratory chemicals etc.
- **Class C fire:** Fires involving flammable gases under pressure including liquefied gases e.g. LPG etc.

- **Class D fire:** Fires involving combustible metals, such as magnesium, aluminium, zinc, sodium, potassium, etc,
- **Class F fire:** Fires involving cooking oils and fats. The characteristic of these fires is that the boiling point of these liquids is quite high (> 200 C) and as the heated oil reaches these temperatures, water cannot be applied as it will convert to steam and cause the burning oil to splash out and increase the fire.

Different types of fire extinguishers are designed to fight above classes of fire. The four most common types of fire extinguishers are: dry chemical type, foam type, water type, CO<sub>2</sub> (carbon dioxide) type. The following figure provides information regarding the type of fire and which fire extinguisher to be used. Fire Extinguishers should be installed in line with IS 15683 requirements.

Type Extinguisher Type	Fire Type					
	Class A Organic Materials (e.g Paper & Coal)	Class B Flammable Liquids (e.g Petrol & Paint)	Class C Flammable Gases (e.g Butane & Methane)	Class D Combustible Metals (e.g Lithium & Magnesium)	Electrical Electrical Equipment (e.g Computers & Servers)	Class F Cooking Oils (e.g Olive Oil & Fat)
Water	✓	✗	✗	✗	✗	✗
Foam	✓	✓	✗	✗	✗	✗
Dry Powder	✓	✓	✓	✓	✓	✗
CO <sub>2</sub>	✗	✓	✗	✗	✓	✗
Wet Chemical	✓	✗	✗	✗	✗	✓


Figure 2: Types of Fire and Suitable Fire Extinguishers



**The principles of fire extinguishment** consist of one of the following three elements:

**1. Starvation:** Starvation is achieved in three ways:

- i. By removing potential fuel from neighborhood of fire. e.g. Draining out fuel from burning tank, counter burning in forest fire, etc.
- ii. By removing the fire from the mass of combustible material for instance, pulling apart burning haystack.
- iii. By dividing burning material into smaller fires which may be left to burn out or which can be extinguished more easily.




**2. Smothering:** In this method, oxygen is excluded in the surrounding atmosphere, thereby leading to fire extinguishment. Smothering can be achieved by using sand, blanketing, or by the use of dry chemical extinguishers.



**3. Cooling:** The most commonly used firefighting medium is water. Water, cools the burning material thereby achieving fire extinguishment. When it is applied to a fire, the extinguishing medium, water itself undergoes changes as it absorbs heat from the fire: (i) Its temperature will rise, (ii) It may evaporate (boil)

Further, smothering effect of the steam produced during boiling process plays important part in fire extinguishment.



## **Where do Fires occur in Hospital Buildings?**

Hospitals have multiple or single building with a large number of patients of different age groups. The most common cases of fires are as under;

- The patient rooms and operation theatres that have combustible materials like cotton beddings, sanitizers, oxygen pipeline connections and the laboratories have chemicals that can easily catch fire.
- Many hospitals have an in-house kitchen. These kitchens have LPG cylinders that could be stored dangerously.
- Hospitals contain laundry rooms, where washing equipments and driers are used. Cotton beddings, clothes etc. are kept in laundry rooms which present an inherent fire hazards.
- Faulty electrical wiring or frayed wires could cause electrical short circuits in hospital. Typically, in modern constructions, these wires are concealed and many times it becomes difficult to track the right source of the fire.

## **How to safeguard Hospitals buildings from fires and human loss?**

- Fire drills should be conducted periodically in Hospital buildings. Fire drills help the hospital staff to understand their roles and responsibilities during a fire emergency.

- Fire exit forms a primary route of egress during a fire emergency. Fire exits should be inspected on regular basis. It should be ensured that stairways, doors are unblocked and working properly.
- Regular training for hospital staff members should be done and fire drills to be conducted, accordingly. Staff members should be trained on how to respond to a fire alarm during a fire drill.
- The firefighting equipment should be readily available during a fire emergency. The location of the firefighting equipment should be identified and the building occupants should be aware of the location of the fire protection equipments, manual call points, smoke detectors.
- An assembly point should be designated outside the hospital building. All the occupants in the building should be aware of the location of assembly point and the path to reach the assembly point.
- Firefighting system, fire alarm system are the means of extinguishing the fire and alerting the occupants. Same should be regularly inspected, maintained and tested.
- Cooking activity should be performed in kitchen only. No other place should be designated as cooking area.
- Laboratory in hospitals handle flammable materials and pressure vessels. It should be ensured that laboratory experiments or pressure vessels should not be left unattended, else there is chances of fire taking place.
- No combustible material of any kind should be stored in the hospital building, except as necessary to normal occupancy and use of the hospital.
- In pharmacy, lot of combustible and flammable material is stored. Adequate housekeeping should be ensured in pharmacy and fire extinguishers should be provided to deal with a fire eventuality.
- Laundry rooms are also part of hospitals. The laundry rooms contain clothes, bed sheets etc. which are washed and subsequently dried. Adequate care should be taken in the laundry rooms to prevent



overheating of the materials from driers. Loose electrical wiring should not be allowed in the laundry rooms.

- Hospitals should use fire retardant material for the curtains, bedsheets, ceiling and wall claddings. Fire retardant materials limit the spread of fire and do not catch fire easily.
- Ventilators and Air conditioners should be serviced periodically. Un-serviced ventilators and air conditioners may lead to fires.
- Electrical points inside the ICU units should be serviced periodically. Un-serviced electrical points may lead to short circuit and fire.
- ELCB and MCB should be used for electrical wirings and electrical connections. ELCB and MCB trip in event of high load conditions, hence they prevent the overheating and fire in an electrical apparatus.
- ICU rooms should have sprinkler system installed and sprinkler system should be serviced periodically.
- ICU rooms should preferably be located on the ground floor and should have alternate exits. Width of the exits should be enough to roll out the beds in event of emergency.
- Ventilators and filters should be installed on the ground level and fresh air intake should be from terrace level.
- Emergency lights with auto starting facility, should be installed in the hospital premises, same should be of amber yellow colour.
- Hospital buildings should not have glass façade. Glass façade may break and impede the safe evacuation of the occupants in event of emergency.
- Hospital buildings should always have a proper functioning fire alarm system. The fire alarm system should be designed in line with the requirements mentioned in the legislation / standards.
- Regular third party fire safety audit should be conducted for the hospital buildings. This helps to understand the areas of improvement in the current systems / practices adopted by hospitals.
- While designing the fire prevention, life safety and fire protection system it should be ensured that the same meets the relevant legislative requirements.
- Ensure Fire Safety Certificate (FSC) is obtained for the building from the local fire authorities, if required.

# Part - B

## **Background:**

Part B of the document provides the basic information to the developer/architects / engineers / designers on what measures to be adopted during construction of the hospital building. The hospital building presents unique fire safety challenges especially for patients, which needs to be focused at the very onset of construction / design of the hospital buildings. This part is divided into three sub-parts i.e. Fire Prevention, Life Safety and Fire Protection measures which need to be taken / installed in the hospital premises. Further reading on requirements of National Building Code (NBC) 2016, Gujarat Fire Prevention and Life Safety Measures Act, Rules & Regulations, General Development Control Regulations (GDCR) & different Indian Standards (IS) is necessary, since this handbook provides only an overview of the fire safety requirements.

## **Institutional occupancy Classification:**

Institutional occupancies are classified as Group C in National Building Code 2016. These buildings are used for medical or other treatment or care of person suffering from physical or mental illness, disease or infirmity; care of infants, convalescents or aged person and for penal or correctional detention in which the liberty of the inmates is restricted. The institutional buildings provide sleeping accommodation to occupants.

### **Subdivision<sup>1</sup>:**

**C1:** Subdivision C-1 Hospitals and sanatoria - This subdivision includes any building or a group of buildings under a group of buildings under single management, which is used for housing persons suffering from physical limitations because of health or age and those incapable of self-preservation, for example, hospitals, infirmaries, sanatoria and nursing homes.

**C2:** Subdivision C-2 Custodial institutions- This subdivision shall include any building or a group of buildings under single management, which is used for the custody and care of persons, such as children, convalescents and the aged who are incapable of self-preservation, for example, homes for the aged and infirm, convalescent homes and orphanages.

---

<sup>1</sup> Subdivision of the Institutional occupancy is based on the use of the occupancy. This subdivision is based on the NBC 2016 (Part IV) requirements.

**C3:** Subdivision C-3 Penal and mental institutions - This subdivision shall include any building or a group of buildings under single management, which is used for housing persons under restraint, or who are detained for penal or corrective purposes, in which the liberty of the inmates is restricted, for example, jails, prisons, mental hospitals, mental sanatoria and reformatories.

As per the NBC 2016, in case of mixed occupancy<sup>2</sup>, i.e. hospital in a mercantile occupancy etc. fire protection of the entire occupancy / building should be governed by most restrictive provision of the entire code. The provision of the life safety should however apply to individual occupancy.

**This document details the fire safety requirements for C1 i.e. Hospital and Sanatoria, buildings only.**

---

<sup>2</sup> Buildings having more than one type of occupancy like – Hospital, Mercantile etc.

## Chapter 1: Fire Prevention Measures

The hospital buildings should be designed and constructed in such a way that, in the event of fire, its stability, integrity and load bearing capacity will be maintained for a reasonable period. The design of the hospital building and the types of material used in its construction are important factors in making the building resistant to a complete burn-out and in preventing the rapid spread of fire, smoke or fumes which may contribute to the loss of lives and property. For further details on fire prevention systems / measures Section 3, section 6.3 & Annex. E of NBC 2016 (Part IV), IS 12433 should be referred.

Non-combustible material should be used for construction of the hospital building, and internal walls of staircase enclosure should be of brick work or reinforced concrete or any material having a fire resistant rating of 120 minute. Load bearing members and non-load bearing members must be constructed to a fire resistant rating as detailed in table 1 of NBC 2016 (Part IV), Section 3 of NBC 2016 (Part IV) and Gujarat Fire Prevention and Life Safety Measures Regulations.

### **Fire Resistant Walls and Floors:**

The fire resistance of an element of construction (such as wall / floor etc.) is a measure of its ability to withstand the effects of fire in one or more ways i.e. its ability to resist collapse, resist penetration from fire / smoke, resist heat transfer during a fire. Fire resistance of a constructional element is defined in minutes or hours e.g. 120 minute or 1 hour. The fire resistance property of an element of construction influences the life safety and property protection requirements.

In hospital buildings, the openings in the fire resistant walls and floors should be sealed to prevent spread of fire / smoke from one area to another. For Type<sup>3</sup> 1 to 3 constructions, a doorway or opening in a fire resistant wall on any floor should be limited to 5.6 m<sup>2</sup> in area with a maximum height/width of 2.75 meter. Every wall opening should be protected with fire-resisting doors, having the fire rating of not less than 120 minute. The openings in the floors must be protected by vertical enclosures extending above and below such openings, such

---

<sup>3</sup> For type of construction of the building, refer Table 1 in NBC 2016 (Part IV)



enclosures having a fire resistance of not less than 120 minute and all openings therein being protected with a fire-resisting assembly.

For Type 4 construction, openings in the fire separating walls or floors must be fitted with 120 minute fire-resistance rated assemblies.

In hospital buildings, openings in walls or floors which are provided for passage of cables, electrical wirings etc. must be protected by enclosure in the form of ducts / shafts with fire resistance rating of 120 minute. The space between the electrical cables / conduits and walls / slabs must be filled with a fire stop material with fire resistant rating of 120 minute



*Figure 3: Fire Stop Material Example*

All vertical openings in the hospital buildings should be suitably enclosed / protected. This should be required to prevent spread of smoke from floor to floor to allow the occupants to evacuate safely.

### **Electrical Installation:**

In hospital buildings, critical electrical cables should continue to function during a fire, this is required since, electrical supply is provided to ICU, operation theatre, patient wards etc. where the patient health monitoring is done on continuous basis. The potential for damage to cables forming circuits should be limited by the use of sufficiently robust cables, careful selection of cable routes and/or by the provision of physical protection in areas where cables may be susceptible to damage. Methods of cable support should generally be non-combustible and such that circuit integrity will not be reduced below that afforded by the cable.

The cables and wires used in hospitals should be with flame retardant property. Electrical cables / wiring should be laid in separate shaft. Electrical cables must not run in shafts containing water mains, gas pipes, telephone lines, intercom lines or similar building service. The shaft should be sealed on every floor with fire stop material with same fire resistant rating as that of a floor.

Medium and low voltage wiring running in shafts, and within false ceiling must run in metal conduit. Any 230 V wiring for lighting or other services, above false ceiling, should have 660 V grade insulation.

Electric meters should not be located below the staircase or along the exit route. Electric meters room should be adequately ventilated & easily accessible.

The electrical installation provided in the hospital buildings should be compliant to the Regulation No. 5A and 30 of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Amendment Regulations, 2015.

Emergency power (i.e. power supply when main electrical power is not working) should be provided to the following equipment / systems:

- Fire pumps.
- Pressurization and smoke venting; including its ancillary systems such as dampers and actuators.
- Fireman's lifts.
- Exit signage lighting.
- Emergency lighting.
- Fire alarm system.
- Public address (PA) system (relating to emergency voice evacuation and annunciation).
- Magnetic door hold open devices.
- Lighting in fire command centre and security room

Power supply to the above systems must be through the normal power and emergency power with changeover facility. The power supply to the panel / distribution board of the above systems must be through fire proof enclosures or circuit integrity cables or through alternate route in the adjoining fire compartment to ensure supply of power is reliable to the above systems and equipment's.

Substation in hospital buildings should not be used for storage of material or material for other utility purposes other than those required for the functioning of the substation. Adequate ventilation must be ensured in substation. Independent AC / ventilation must be provided for MV (Medium voltage) panel room located on the ground level or first basement. The MV panel room must be provided with fire resistance of not less than 120 minute

In hospital buildings, the substation / switch station with oil filled equipment should be located at least 7 meter away from the adjoining buildings. All oil filled transformers exceeding 10 MVA capacity must be protected with high velocity water spray system or nitrogen injection system. Transformer located inside the hospital buildings should be of dry type.

Diesel generator (DG) set must not be installed on ground floor / first basement of the hospital buildings. The DG set if installed indoor, proper ventilation and exhaust should be planned. The DG set rooms should have 120 minute fire resistance rating. For detailed information regarding fire safety requirements for hazardous petroleum products, reference may be made to The Petroleum Act, 1934 and the Rules framed there under.

Lightning protection of the hospital buildings should be ensured by routing of down conductors (insulated or uninsulated) through electrical shafts. For further details, see Part 8 "Building Services, Section 2 Electrical and Allied Installation" of the NBC 2016 and Central Electricity Authority (Measures relating to Safety and Electric Supply) Amendment Regulations, 2015.

### **Escape Lighting and Exit Signage:**

In the hospital buildings, exit access, exits and exit discharge should be properly identified and continuously illuminated. Emergency lighting should be provided from an independent source i.e. from different source supplying normal lighting. The horizontal luminance at the floor level on the escape route must be not less than 10 lumens / m<sup>2</sup>. Required illumination should be arranged such that failure of any single luminary will not leave any area in darkness. The emergency lighting should be provided to be put on within 5 second of the failure of the normal lighting supply. Also, emergency lighting should be able to maintain the required illumination level for a period of not less than 90 minutes in the event of failure of the normal lighting even for smaller premises. The emergency

lighting system should be well maintained and periodically inspected and tested to ensure perfect serviceability.

In hospital buildings, exit access corridors / paths must be provided with exit signage. The exit signs should be located such that no point in exit access is more than 30 meter of viewing distance. The exit sign indicating the direction should be installed in all changes of direction. Exit signs should be illuminated and wired to an independent electrical circuit on an alternative source of supply. All exit way marking signs should be so installed that no mechanical damage should occur to them due to moving of furniture or other heavy equipment. Further, all landings of floor should have floor indicating boards prominently indicating the number of the floor. The sizes and colours of the exit signs should be in accordance with IS 9457, IS 12349, IS 12407. The colour of the exit signs should be green.



*Figure 4: Exit Signage*

### **Air Conditioning, Ventilation and Smoke Control:**

In hospital buildings, the system of mechanical ventilation should be designed to ensure that, in a fire, the ductwork does not assist in transferring fire, smoke and fumes through the building and put at risk the protected means of escape and patient areas. Any exhaust points should be sited so as not to further jeopardize the building, i.e., away from exits, combustible building material or roofing materials and openings into the building.

In hospital buildings, separate Air Handling Unit (AHU) should be provided for each floor so as to avoid the hazards arising from spread of fire and smoke through the air conditioning ducts. The air ducts should be separate from each

AHU to its floor and in no way should interconnect with the duct of any other floor.

In hospital buildings, shafts or ducts, if penetrating multiple floors, must be of masonry construction with fire damper in connecting ductwork or should have fire rated ductwork with fire dampers at floor crossing. Alternatively, the duct and equipment may be installed in room having walls, doors and fire damper in duct exiting/entering the room of 120 minute fire resistance rating. The air filters of the air handling units should be made of non-combustible materials.

In hospital buildings, air ducts serving main floor areas, corridors, etc, should not pass through the exits/exit passageway/ exit enclosure. Wherever the ducts pass through fire walls or floors, the opening around the ducts should be sealed with material having the fire resistant rating of the compartment. The materials used for insulating the duct system (inside or outside) should be of non-combustible type. Any such insulating material should not be combustible in nature.

Fire or Fire/smoke dampers<sup>4</sup> should be provided in supply air ducts, fresh air and return air ducts/ passages. The damper should be so installed to provide complete integrity of the compartment with all passive fire protection sealing. Damper should be accessible to maintain, test and also replace, if so required. There should also be provision for manual operation of the dampers.

The dampers should be located in supply air ducts, fresh air and return air duct / passages at the following points:

1. At the fire separation wall<sup>5</sup>
2. Where ducts / passages enter the vertical shaft.
3. Where the ducts pass through floors and
4. At the inlet of the supply air duct and the return air duct of each compartment on every floor.

---

<sup>4</sup> A device installed in ducts and air transfer openings of an air distribution or smoke control system designed to close automatically upon detection of heat / smoke.

<sup>5</sup> A fire resistant rated wall having fire protected openings, which restrict the spread of fire and extends continuously from the foundation to the roof (and through the roof at least 1 meter above the roof in case of combustible roof), with sufficient structural stability under fire conditions to allow collapse of construction on one side or either side without collapse of the wall

## Glazing:

In hospitals, no glass facades should be permitted.

## Surface Interior Finish:

Interior finishes in the hospital buildings have been a leading factor in flame spread. Interior finishes are considered to consist of those materials or combination of materials that form the exposed interior surfaces of walls and ceilings in a building.

In hospitals the use of combustible surface finishes on walls, ceilings and curtains used inside patient rooms as a separation between two patients, affects the safety of the occupants. Such finishes tend to spread the fire and add intensity to the fire. It also produces toxic fumes and leads to property damage. It is essential that the finishing material used in the building should be such as to limit the spread of fire and should not generate toxic fumes / smokes.

## Fire Command Centre (FCC):

In hospitals, the fire command centre should be located on the entrance floor, having direct access. The fire command centre should have main fire alarm panel with communication system (and public address system).

The fire command centre should be constructed of 120 minute fire resistant rated walls and with fire doors and should be provided with emergency lighting. Interior finish used in fire command centre should not be combustible. Details of floor plans along with the details of fire fighting equipment and installations should be maintained in fire command centre.




## Chapter 2: Life Safety Measures

Life safety measures are made up of elements that are designed to protect patients, hospital staff and visitors in the hospital during a fire situation. There are many components that make up life safety systems in a building. Having an integrated and fully functioning life safety system can improve the safety in the hospital buildings. Life safety can be termed as strategies / methods to protect occupants in buildings based on building construction, protection, and occupancy features that minimize the effects of fire and related hazards.

The life safety measures in a hospital building mainly consist of means of egress requirements, compartmentation, smoke control systems, Gas supply systems, fire detection and alarm system, Fire drills, fire orders, lifts. For further details on life safety systems it is advised to read section 4 & 6.3, Annex. E in NBC 2016 (Part IV), IS 12433, Gujarat Fire Prevention and Life Safety Measures Regulations.

### Means of Egress Requirements:

In a hospital building the means of egress comprises of exit access, exits and exit discharge. These components play a major role for a safe evacuation of the occupants in the hospital premises. All three components i.e. exit access, exit and exit discharge must be maintained obstruction free and in working condition. Now let us look into the details of the egress components and important features highlighted in NBC 2016 (Part IV).




*Figure 5: Means of Egress, Exit, Exit Discharge*

Exit access is defined as the portion of the means of egress that leads from an occupied portion to an exit. Exits are components like doorways, staircases etc. which is between the exit access and exit discharge or public way. Exits are separated by fire resistant rated construction and opening protectives to provide a protected path of egress travel. Exit components include exterior exit doorways, exit passageways, exterior exit stairways, exterior exit ramps etc. Exit discharge is defined as component of a means of egress between the termination of exit and public way.

Every exit, exit passageway and exit discharge must be maintained obstruction free, to aid free movement of the patients, staff and visitors during an emergency.

All the exit and exit passageways to exit discharge must have a clear ceiling height of at least 2.4 meter. However, the height of exit door should be at least 2.0 meter. The width of exits from hospital or infirmary sections should be minimum 2 meter.




**Figure 6: Exit Height**

In hospital buildings, the capacity of the means of egress need not be reduced along the path of egress travel until arrival to the exit discharge. Wherever changes in elevation are envisaged for more than 300 millimeter, ramps with handrails must be provided. Floor finish of ramps should contrast the adjacent finish material. Penetrations such as fire protection piping, ducts for pressurization and for life safety systems should only be allowed in exits, with adequate passive fire protection.



Walking surface along the exit access must meet the following requirements:


1. Levelled and slip resistant surface.
2. Slope should not exceed 1 in 20, unless ramp is provided.
3. Slope perpendicular to the direction of travel should not exceed 1 in 48.



*Figure 7: Ramp Slope*

In hospitals, the number of escape routes and exits to be provided will depend on the occupant load<sup>6</sup> (i.e. number of people) in the room or storey and the limits on travel distance to the nearest exit as mentioned in NBC 2016 (Part IV).

For hospitals requiring more than one staircase, it must be ensured that, every part of each storey will have access to more than one staircase. This does not prevent areas from having a dead end condition provided that the alternative stair is accessible in case the first one is not usable. Though dead end corridors are not desirable, however maximum distance to a dead end should not exceed 6m.



*Figure 8: Dead End*

<sup>6</sup>The total number of people that might occupy a building or space at any point of time.

Travel distance to the nearest exit should be limited to the NBC 2016 (Part IV) requirements. There are benefits to limit the travel distance like -

- Limited travel time; safety may be reached without serious exposure to smoke;
- Limited size and complexity of enclosure;
- Provision of sufficient alternative escape capacity within a reasonable distance. increased likelihood that an exit is visible, and remains so during a fire;
- Reduced likelihood that a fire can occur unseen, or grow large before detection/alarm; and
- Reduced likelihood of a fire between occupant and exit.

The maximum travel distance from any point within the building to a final exit should not exceed the limits mentioned in NBC 2016 (Part IV). If the travel distance limits are exceeded, then one more exit provision should be made.

	Maximum Travel Distance	
	Type 1 / Type 2	Type 3 / Type 4
Hospital Building	30	22.5

**Note:**

- For sprinklered building, the travel distance may be increased by 50 percent of the value specified.
- Ramps should not be counted as an exit in case of basement below the first basement in car parking.




Figure 9: Travel Distance Calculation

The occupant load factor mentioned in NBC 2016 (Part IV) should be used as the basis for arriving at the occupant load of a floor / room in the hospital. When the number of occupants likely to use a room or storey is not known, the capacity should be calculated on the basis of the appropriate floor area & occupant load factors as per NBC 2016.

The number of occupants (occupant load) arrived from table 3 of NBC 2016 (Part IV) is the number of persons during the normal level of occupancy in a room or storey. If the number of occupants are anticipated to exceed, then the exit design should consider the increased occupant load.

**Example:**

As per NBC 2016 (Part IV), the occupant load factor for a hospital room (Indoor patient area) is 15 m<sup>2</sup>/person. Assume the area of the room is 150 m<sup>2</sup>.

The occupant load for the room will be  $150 / 15 = 10$  persons. Hence the exit requirements will be based on 10 persons, subject to minimum requirement stated

If it is anticipated that the number of occupants in the room is 40 instead of 10, then the exit requirements will be based on 40 persons.

The width of escape routes and exits depends on the number of persons needing to use them. The aggregate width of all the escape routes should be not less than that required to accommodate the maximum numbers of people likely to use them. Where the maximum number of people likely to use the escape route and exit is not known, the appropriate capacity should be calculated on the basis of the occupant load factor mentioned in NBC 2016 (Part IV).

**Example:**


The width of the escape route should be calculated based on the capacity factors for stairways i.e. 15 millimeter / person and for level components / ramps i.e. 13 millimeter / person.

Example an exit doorway with 1000 millimeter clear width will have an exit capacity for  $1000 / 13$  occupants that is 77 persons.

## Exit components:

### Doorways

Exit doorways in hospital buildings must open into an enclosed stairway or horizontal exit of a corridor or passageway, and should always be operable from direction of egress.



*Figure 10: Doorway Opening*

In hospital buildings, minimum height of doorway should be 2 meter (height), the width of door should depend on the number of patients beds kept in the room.

Measures incorporated into the design of a hospital building to restrict access to the building or parts of it should not adversely affect fire safety provisions. All critical patients and those incapable of self-preservation and having physical impairment should be housed within 30 meter of the building height. Other types of patients and occupancies incidental to hospitals such as consultation rooms, nurse station, medical shops, canteens etc. should be housed beyond 30 meter and less than 45 meter height. Basement should not be used to store flammable or pathological or other laboratories particularly involving use of chemicals.

In hospital building, the activation of the building automatic sprinkler system or fire detection system should automatically unlock the access control system. Any loss of power must unlock the access control system. A manual release device must be provided near the access control doorways with signage "Push to Exit".


Any sleeping accommodation or suite exceeding 100 m<sup>2</sup> in area shall have at least two doorways leading to the exit access corridors.

## Corridor and Passageways of Means of Egress:

For hospital building, width of the corridor must be not less than the aggregate width of exit doorway leading from them. The width of the corridor and aisle through which patient are moved should be minimum 2.4 meter. The width of corridor and aisles not intended for the housing, treatment or use of inpatients<sup>7</sup> should be not less than 1.5 meter width.

Wherever there is central corridor, which is part of exit access, the doors of rooms must open inwards.

The floor surface of the corridor should not be inclined at a gradient steeper than 1 in 12 to the horizontal.




*Figure 11: Doorway Opening in Corridor*

## Staircase:

In hospital buildings, the flights and landings of every escape stair should be constructed of non-combustible material. All hospital buildings must have minimum 2 staircases.

<sup>7</sup> The inpatient areas are one where patients lives in hospital while under treatment.

Dimensional constraints on the design of stairs are kept, to meet requirements for safety while using staircase. The preferred rise for each step should be not more than 150 millimeter, and the tread 300 millimeter and there should be between maximum 12 riser per flight.



*Figure 12: Riser and Tread of Staircase*

Internal staircase<sup>8</sup> inside the hospital building must be constructed of fire resistant material with minimum 120 minute fire resistant rating.

Internal staircase should not be arranged around a lift. Lift must not open inside a staircase. No electrical shaft / AC ducts / gas pipelines should pass through the staircase.

The minimum width of the internal staircase must be 2 meter. Handrail must not project more than 90 millimeter. The Floor indication board should be pasted inside the internal staircase, with a minimum size of 300 millimeter X 200 millimeter.



*Figure 13: Staircase Indication Board*

<sup>8</sup> It is a staircase which is inside the premises of the building, and leads a to inside of the building.

All external staircase<sup>9</sup> must be connected to the ground.

External staircases must be constructed of non-combustible material and staircase must be kept in usable conditions. The external staircase must not be blocked / obstructed under any condition.

External staircase must have a flight of not less than 1500 millimeter wide.



*Figure 14: External Staircase*

### **Ramps:**

Ramps are sloped surfaces inside / outside of the hospital buildings to aid access to vertical levels. These are specifically made for physically challenged people with mobility issues and for stretcher movement.

In hospital buildings, ramp width should not decrease along the direction of travel and slope should not exceed 1 in 12 inch. The ramp surface should be slip resistant and water accumulation should be minimised. The width of the ramps through which patient are moved should be minimum 2.4 meter. The width of the ramps not intended for the housing, treatment or use of inpatients should be not less than 1.5 meter width. The ramps should be provided with handrails on both sides. For further guidance on ramps refer Part 3 "Development Control Rules and General Building Requirements" of NBC 2016.

<sup>9</sup> It is a staircase which is open to outdoor and leads directly to the exterior of the building.

## **Smoke Control Systems:**

Smoke control in hospital building play a very vital role in ensuring the life safety of the occupants in air tight buildings. The purpose of smoke control is to reduce the build-up of smoke within an enclosed space in order to provide the occupants of building sufficient time to escape to a safer area in the building or outside the building. Smoke control systems are also designed to reduce the rate of growth of the smoke in a fire affected zone such that height of smoke layer does not impair the movement of occupants from hazardous area.

In hospital building, one of the means to achieve smoke control is through pressurization. Pressurization is adopted by protecting the exits from ingress of smoke, especially in high rise building. In pressurization air is injected into the staircase, lobbies etc, to raise the pressure slightly above the pressure in adjacent parts of the building.

The pressurization system is initiated by the fire alarm panel. Once a fire alarm panel receives a signal from detection system or manual signal regarding a fire in any premises, the pressurization system is actuated to ensure escape of the hospital occupants. Pressurization system is not required for a naturally ventilated corridor with openable windows.

In hospital buildings, the other method for smoke control is the exhausting of the smoke as it gets accumulated in a layer in the exit pathway, atria etc. In this method of smoke control, the design for rate of smoke extraction must be equal to the rate of smoke generation. The air intake ducts should be located 5 meter away from the smoke exhaust ducts. Smoke exhaust system must ensure atleast 12 air changes per hour in the area affected by fire / smoke.

For further guidance on smoke control systems refer Part 8 "Building Services, Air Conditioning, Heating and Mechanical Ventilation" of NBC 2016.






Figure 15: Staircase Pressurization System





Figure 16: Smoke Exhaust System

## Compartmentation:

In hospital buildings, compartmentation is an important component of the fire safety design as it aims to divide large spaces into smaller and manageable fire compartments. Fire compartmentation is used to create a safe, protected means of escape for the hospital occupants in the event of a fire. Generally, these fire compartments are separated from each other by compartment walls and compartment floors made of a fire-resisting construction which acts as a barrier to the spread of fire and smoke for a specific period of time. Operation theatres, delivery rooms, intensive care units, recovery rooms, etc, that contain patient lacking self-preservation in case of emergencies should be fire/smoke <sup>10</sup> separated (120 minute rating) from all the adjoining areas.

All floors should be compartmented with area of each compartment equal to 1800 m<sup>2</sup>. The compartmentation should be achieved by a fire barrier wall of 120 minute fire rating.



*Figure 17: Fire Compartment in Building*

## Gas Supply:

In hospitals, gas pipelines are installed to supply natural gas / LPG to the kitchens. The gas pipelines should always run in separate shafts in the building premises. The gas pipeline shafts should run on external walls and away from staircases. The pipeline length should be as short as possible. Emergency valves to shut off the gas supply connection should be located in accessible location.

<sup>10</sup> Fire / smoke separation is accomplished by using fire barrier / smoke barrier (horizontally and vertically) which restrict the spread of fire and movement of smoke.

Wherever gas cylinder manifold is installed in the hospital premises, same should be adequately ventilated. Kitchens working on the LPG fuel should not be located in basements.

For further guidance on gas pipeline installation refer Part 9 “Plumbing services, section 4 gas supply” of NBC 2016.

### **Fire Detection and Alarm System:**

The purpose of fire detection and alarm system in building is to provide early warning and intimation regarding fire situation to the occupants of the building. The fire detection and alarm system consist of smoke detectors, heat detectors, manual alarm call points, visual and audible warning system, fire alarm panels etc.

The fire detection and alarm system in building should be programmed with fire alarm panel to operate smoke control systems, hold up of the fire doors, visual and audible warning systems etc. All components of the fire alarm and detection system must be maintained and ensured in healthy working condition.

In buildings provided with automatic fire alarm system, following must be monitored:

- Water level in tanks
- Hydrant and sprinkler pressures of respective zones as provided
- Pump “ON/OFF” status
- All isolation valves, wherever provided with supervisory switch

For further guidance on smoke control systems refer Part 12 “Asset and Facility Management” of NBC 2016 & IS 2189.



*Figure 18: Smoke Detector*



*Figure 19: Manual Call Point*

## **Fire Safety Executive, Fire Drills and Fire Orders:**

In hospitals above 15 meter height, a qualified fire safety executive, with experience not less than 3 years, must be appointed. The fire safety executive should be responsible for following:

- Maintain the fire fighting equipment in hospital in good working condition.
- Prepare fire orders and fire operational plans and promulgated.
- Impart training to the staff in hospitals for use of fire fighting equipment and keep them informed about fire emergency evacuation plan.
- Keep liaison with the fire brigade.
- Ensure that all fire precautionary measures are observed at all times.

Fire orders / fire notices should be prepared to fulfil the requirements of fire fighting and evacuation from the building in event of fire and other emergency. Principle of progressive horizontal evacuation is important in the hospitals for patients lacking self-preservation. This calls for moving the occupants from a fire affected area to an adjoining area at the same level through a fire resistant wall to protect them from the immediate dangers of fire and smoke. The progressive horizontal evacuation operates on the basis of evacuation from one compartment to another compartment and on use of adjacent compartments as temporary means of refuge<sup>11</sup>. The staff of the hospital must be made thoroughly conversant with their action during fire emergency and fire notices pasted at prominent locations and regular training must be imparted. For guidelines for fire drills and evacuation procedures for hospital buildings qualifying as high rise buildings refer annex. D of NBC 2016 (Part IV).

### **Lift :**

In hospital buildings, lifts are used for vertical travel by occupants and patients. Lift should not be used in case of emergency by any occupants of the hospital premises. The stretcher lift in a lift bank should also act as fireman lift in event of emergency. Additional requirements for lifts can be referred in Part 8 "Building services, Section 5 Installation of Lifts, Escalators and Moving Walks, Subsection 5A lifts" of NBC 2016.

---

<sup>11</sup> An area within the building for a temporary use during egress. It generally serves as a staging area which is protected from the effect of fire and smoke.

## Chapter 3: Fire Protection Measures

Hospitals must have proper fire protection system<sup>12</sup> in place for occupants of the building to be protected in event of fire emergency. Depending on the height, number of storey and area, NBC 2016 (Part IV) details the necessary fire protection measures required for hospital buildings. For further details on fire protection systems, it is advised to read section 5 in NBC 2016 (Part IV), Annex. E in NBC 2016 (Part IV), IS 12433, IS 15325, Gujarat Fire Prevention and Life Safety Measures Regulations.

The fire protection measures to be considered for the hospital buildings may include the following:

### Fire Extinguishers:

Fire extinguishers are the first line of defence against a fire. Fire extinguishers should be installed throughout the hospital premises. Fire extinguishers should be mounted at a convenient height. The fire extinguishers should be suitable to the fire hazard anticipated in the area. e.g. near an electrical apparatus CO<sub>2</sub> type fire extinguisher should be installed, in laboratory DCP type fire extinguisher should be installed. Further details on selection, installation and maintenance of fire extinguisher IS 15683 and IS 2190 should be referred.



*Figure 20: Fire Extinguishers*

<sup>12</sup> A system of fire protection which comes into action once there is a fire. This system consist of actions to control the effects of fire.

### First Aid Hose Reel:


The first aid hose reel should be installed on the downcomers / wet risers installed in the hospital premises. The first aid hose reels are the first line of defence for incipient stage fires. Minimum diameter of the hose reel should not be less than 19 mm.



*Figure 21: First Aid Hose Reel*

### Wet Risers:

An arrangement of fire fighting in the building by means of vertical fire water line with diameter not less than 100 millimeter and fire hydrant valves on each floor / landing. Wet risers are permanently charged with water. The wet risers are fed with fire water pumps. The pressure available at the hydrant points should be between 3.5 to 7 bar. Fire hose should be connected to the hydrant landing valves to supply water at the site of fire. Trained personnel should handle the fire hose connected to the wet risers.



*Figure 22: Wet Riser*

### **Downcomer:**


An arrangement of firefighting within the hospital premises by means of down-comer pipe connected to terrace tank through terrace pump, gate valve and non-return valve and having mains not less than 100 millimeter internal diameter with landing valves on each floor/landing. It is also fitted with inlet connections at ground level for charging with water by pumping from fire service appliances and air release valve at roof level to release trapped air inside. The pressure available at the hydrant points should be between 3.5 to 7 bar. Trained personnel should handle the fire hose connected to the wet risers.



*Figure 23: Downcomer*

### **Yard Hydrant:**

A network of fire hydrant installed in the premises outside the hospital building. The yard hydrant network is fed through fire water pumps. The pressure in the yard hydrants should not exceed 7 bar. Fire hose should be connected to the yard hydrants to supply fire water to the fire area. Trained personnel should handle the fire hose connected to the yard hydrants.



*Figure 24: Yard Hydrant*

### **Automatic Sprinkler System:**

One of the most important part of fire protection is a fire sprinkler system. A properly designed and functional fire sprinkler system can prevent fire from spreading to different parts of building, help in ensuring life safety and reduce property damage. Automatic sprinklers should be installed in all areas except in substation and DG set area. Pressure in sprinkler system should not exceed 12 bar. The Sprinkler system flow switches must be monitored from fire alarm panel. Provision should be made to ensure water from sprinkler do not enter the lift and electrical rooms. Sprinkler system control valve must be installed in fire pump room.



*Figure 25: Automatic Sprinkler System*

### **Manual Operated Electronic Fire Alarm System (MOEFA):**

MOEFA systems include the manual call points, talk back system and public address systems installed in the hospital buildings. The purpose of the MEOFA systems is to provide early warning to the occupants.

### **Automatic Detection and Alarm System:**

This system comprises of components to automatically detect fire, heat, smoke in the hospital buildings. The automatic detection and alarm system should be



kept operational 24 X 7. It is essential that fire detection and warning systems are properly designed, installed and maintained. Alarm systems should be standardised across a building.

### **Underground Static Fire Water Storage Tank:**

Water for fire fighting purpose should be stored in the fire water storage tanks. The fire water tanks should be filled to the complete capacity and maintained on 24 x 7 basis. Water should be stored in two or more interconnected compartments of equal size to facilitate cleaning and maintenance. The static water storage must be easily accessible to the fire engines. The underground fire water storage tank must not be more than 7 meter deep from the level of fire draw of connection. The covering slab of the storage tank should be able to withstand 45 ton (or as applicable) vehicular load. The static water storage should be provided with fire brigade collecting head and a fire brigade tank filling connection.

### **Terrace Tank over respective towers:**

Water for fire fighting may be stored in overhead terrace tanks located on hospital towers. The fire water tanks should be filled to the complete capacity and maintained on 24 x 7 basis. Water should be stored in two or more interconnected compartments of equal size to facilitate cleaning and maintenance.

### **Fire Water Pumps:**

It is preferable to install the fire water pumps at ground level. The fire water pump house should be accessible from ground level. The fire water pumps should not be installed in second basement. The fire water pumps should be kept operational at all times. The fire water pump house should be separated by fire wall all around and doors should be protected by fire doors (120 minute) rating. The pump house should be well ventilated and care should be taken to prevent water stagnation. The fire water pump house should not have negative suction arrangement and submersible pumps should not be used. Fire water pumps house should be sufficiently large to accommodate all pumps and supporting

accessories. Exhaust of the diesel engine should be insulated and routed to a safe location at ground level.

### **High Velocity Water Spray System:**

Automatic high velocity water spray system should be installed on transformers in line with requirements of IS 15325.

Following **requirements relating to the fire protection** features should be considered for hospital buildings, based on NBC 2016 (Part IV) Table 7:

Sr. No.	Hospital Building (Note 5)	Type of Installation								Water Supply (Litre)		Pump Capacity (litre/ minute)	
		Fire Extinguisher	First Aid Hose Reel	Wet Riser	Down Comer	Yard Hydrant	Automatic Sprinkler System	Manually Operated Electronic Fire Alarm System (Note 1)	Automatic Detection System (Note 2)	Under-ground storage tank	Terrace tank over respective tower	Pump near underground storage tank (minimum 3.5 bar pressure at remotest point)	Pump at terrace tank with minimum pressure of 3.5 bar
a.	Hospital, Sanatoria and Nursing homes (C-1)												
1.	Less than 15 m in height with plot area up to 1000m <sup>2</sup> .												
	i. Up to ground plus one storey, with no beds	R	NR	NR	NR	NR	R (Note 3)	R	NR	NR	(5000) Note 4	NR	(450) Note 4
	ii. Up to ground plus one storey, with beds	R	R	NR	NR	NR	R (Note 3)	R	NR	NR	5000 (5000) Note 4	NR	450 (450) Note 4
	ii. Ground plus two or more storeys, with no beds	R	R	NR	R	NR	R (Note 3)	R	R	NR	10000 (5000) Note 4	NR	900 (450) Note 4
	v. Ground plus two or more storeys, with beds	R	R	R	NR	NR	R	R (Note 1)	R	75000	10000	Note 6	NR
2	Less than 15 meter in height with plot area more than 1000m <sup>2</sup>	R	R	R	NR	R	R	R (Note 1)	R	100000	10000	Note 6	NR

Sr. No.	Hospital Building (Note 5)	Type of Installation								Water Supply (Litre)		Pump Capacity (litre/ minute)	
		Fire Extinguisher	First Aid Hose Reel	Wet Riser	Down Comer	Yard Hydrant	Automatic Sprinkler System	Manually Operated Electronic Fire Alarm System (Note 1)	Automatic Detection System (Note 2)	Under-ground storage tank	Terrace tank over respective tower	Pump near underground storage tank (minimum 3.5 bar pressure at remotest point)	Pump at terrace tank with minimum pressure of 3.5 bar
3	15 meter and above but not exceeding 24 meter height	R	R	R	NR	R	R	R	R	15000 0	20000	Note 8	NR
4	Above 24 meter and not exceeding 45 meter in height.	R	R	R	NR	R	R	R	R	20000 0	20000	Note 9	NR

R = Required  
NR = Not Required

**Notes:**

- MOEFA must also include talk back system and public address system for hospital buildings in a (1) (4) & a (2), 15 meter and above. Also same to be installed in car parking area greater than 300 m<sup>2</sup> and multi level car parking area.
- Automatic detection and alarm system is not required to be provided in car parking area. Such detection system should however be required in other areas of car parking such as electrical rooms, cabins and other areas.
- Required to be installed in basement, if area of basement exceeds 200 m<sup>2</sup>.
- Additional value given in parenthesis should be added if basement area exceeds 200 m<sup>2</sup>
- Maximum height of the hospital building must be in accordance with Gujarat Fire Prevention and Life Safety Measures Regulations.
- Provide required number of sets of pumps each consisting of one electric and one diesel pump (stand by) of capacity 1620 litre / minute and one electric pump of capacity 180 litre /minute. (See also note 7)
- One set of pumps shall be provided for each 100 hydrants or part thereof, with a maximum of two sets. In case of more than one pump set installation, both pump sets shall be interconnected at their delivery headers. Alternative to the provision of additional set of pumps, the objective can be met by providing additional diesel pump of the same capacity and doubling the water tank capacity as required for one set of pumps.
- Provide required number of sets of pumps each consisting of one electric and one diesel pump (stand by) of capacity 2280 litre / minute and one electric pump of capacity 180 litre /minute. (See also note 7)
- Provide required number of sets of pumps each consisting of two electric and one diesel pump (stand by) of capacity 2280 litre / minute and two electric pump of capacity 180 litre /minute. (See also note 7)

## **Fire Safety Inspection Checklist for Hospital Buildings:**

<b>Sr. No.</b>	<b>Item</b>	<b>Yes</b>	<b>No</b>	<b>NA</b>	<b>Remarks</b>
<b>Exits</b>					
1	Are all exits free from obstructions or impediments?				
2	Are all exits unlocked and can be readily open in direction of travel?				
3	Can all egress doors open fully?				
4	Are exits signs in place, visible and illuminated?				
5	Are the shafts and electrical cable openings in the floors / walls sealed with fire stop material?				
6	Is there any combustible material storage in exit, exit corridors and in areas other than designated storage rooms?				
7	Is glass façade installed in the hospital building?				
8	Is the ICU located at the ground floor level, does it have alternate exit provision, wide enough to roll the bed in ICU?				
<b>Electrical Safety</b>					
9	Is the electrical cable and wiring having a fire retardant property?				
10	Are all electrical system maintained and there are no loose or open wirings?				
11	Are ELCB / RCCB / GFCI / MCB / electrical points present in the electrical system maintained and tested?				
12	Is the installed electrical load in the building as per the sanctioned load?				
13	Are air conditioner and ventilators present in the hospital building maintained?				

Sr. No.	Item	Yes	No	NA	Remarks
<b>Fire Fighting Systems</b>					
14	Are all emergency lights in auto starting mode and have amber yellow colour.				
15	Are all emergency power systems tested and inspected on regular basis?				
16	Are the fire extinguishers installed as per the anticipated fire hazard?				
17	Are the fire extinguishers tested on periodic basis?				
18	Is the fixed fire protection system (Fire pumps, downcomers, wet risers, hydrant valves, first aid hose reels, automatic sprinkler systems) maintained and in working condition?				
19	Is the fire water storage tank cleaned on periodic basis?				
20	Is the ICU sprinklerd?				
<b>Fire Detection System</b>					
21	Is the fire detection system installed in building and in working condition?				
22	Is the fire detection system installed in building tested and inspected on periodic basis?				
23	Is the fire alarm system in working condition?				
24	Is the fire alarm system inspected and tested on periodic basis?				
<b>Emergency Preparedness</b>					
25	Are regular fire evacuation drills conducted in building?				
26	Is there a documented emergency management plan?				
27	Are all hospital staff trained in usage of fire extinguishers / fixed fire protection systems?				
28	Are all hospital staff provided training				

Sr. No.	Item	Yes	No	NA	Remarks
	on emergency preparedness?				
29	Are all hospital staff aware of the roles and responsibilities during emergency, and whether same has been documented?				
30	Are emergency evacuation plans pasted in building?				
31	Is there a public address system installed in building and is it working?				
<b>General Points</b>					
32	Are all curtains, bedsheets, ceiling and wall claddings made of fire retardant materials?				
33	Are all ventilators and filters installed at ground level and fresh air intake ducts inducted at terrace level?				
34	Is fire safety executive appointed in building?				
35	Are periodic fire safety audits undertaken for hospital building?				
36	Is FSC (Fire Safety Certificate) obtained for building?				

## Do's and Don'ts during Fire Emergency

### Do's

- Don't panic and stay calm.
- Raise alarm and alert everyone in the premises
- Escape first and then call for help.
- Use nearest available exit route.
- While leaving the premises, close all doors and windows behind you if possible but must ensure that nobody is left behind and you are safe.
- Know the location of the oxygen shut off valve and electrical supply, located in the hospital premises.
- Only the staff who are trained for the progressive horizontal evacuation procedure should move the patients to the safe area.
- Use only escape route as they are built for the egress purpose
- Use staircase, "Don't use lifts".
- If you are trapped in room, close the door and block the gaps which might let smoke and fumes come inside.
- Shout from window to attract the attention of the rescue team as well as others.
- Always crawl low under the smoke and try to keep your mouth covered.

### Don'ts

- Never stand up in fire.
- Never go back into burning building for any reason.
- Don't secure open fire and smoke check doors as they limit the spread of fire and smoke when they are in closed position.
- Don't be tempted to clutter the stairs, corridors and lobbies as they are your escape routes.
- Never use lift in case of fire, always use staircase.
- Don't shout or run. This tends to cause panic to others.



## Link to Important Documents

<b>Sr. No.</b>	<b>Description</b>	<b>Link</b>
<b>1</b>	National Building Code – 2016	<a href="https://gidm.gujarat.gov.in/codes-and-standards-related-fire-safety">https://gidm.gujarat.gov.in/codes-and-standards-related-fire-safety</a>
<b>2</b>	IS 15683: Portable fire extinguishers – Performance and construction	
<b>3</b>	IS 2190: Selection, installation and maintenance of First aid fire extinguishers.	
<b>4</b>	IS 15105: Design and Installation of fixed automatic sprinkler fire extinguishing systems—code of practice	
<b>5</b>	IS 9457: Safety colours and safety signs - Code of Practice	
<b>6</b>	IS 12349: Fire protection-safety signs	
<b>7</b>	IS 12407: Graphic symbols for fire protection plans	
<b>8</b>	IS 15325: Design and installation of fixed automatic high and medium velocity water spray system - code of practice	
<b>9</b>	IS 12433: Basic requirement for hospital planning.	

**Save yourself, save others  
Be prepared and stay alert!**







**Directorate of State Fire Prevention Services,  
Government of Gujarat**

## **Gujarat Institute of Disaster Management**

Koba-Gandhinagar Road, B/h Pandit Deendayal Energy University,  
Village – Raisan. Gandhinagar—382007. Gujarat, India.

Ph. (079) 23275804 to 25 | Fax: (079) 23275814

Email: [info-gidm@gujarat.gov.in](mailto:info-gidm@gujarat.gov.in) | Website: [www.gidm.gujarat.gov.in](http://www.gidm.gujarat.gov.in)