

(4) FASTENERS THROUGH BLOCK
BOTTOM FLANGE TO BEARING
SUPPORT PER TABLE T.1

BEARING SUPPORT
BY OTHERS

3-1/2" (MIN)
BEARING

ClarkDietrich BUILDING SYSTEMS
TradeReady® JOIST PER PLAN

OPTION 1-DIRECT JOIST/BLOCK ATTACHMENT

ClarkDietrich BUILDING SYSTEMS
S547 WITH (4) SCREWS AS REQUIRED,
TO BLOCK AND (4) FASTENERS
PER TABLE T.1 TO BEARING SUPPORT

BEARING SUPPORT
BY OTHERS

3-1/2" (MIN)
BEARING

ClarkDietrich BUILDING SYSTEMS
TradeReady® JOIST PER PLAN

OPTION 2-JOIST/BLOCK ATTACHMENT WITH CLIPS

TABLE T.1

SUPPORT TYPE	SUGGESTED FASTENER
STRUCTURAL STEEL, CONCRETE OR CMU BEARING	0.145"Ø P.D.F.
WOOD	#8(MIN) APPROPRIATE SCREW
LIGHT GAUGE METAL FRAMING	#10-16 SCREWS

NOTES:

- 1) ATTACH BLOCKING TO SHEATHING
W/(4) #8 SCREWS OR EQUIVALENT.
- 2) BLOCK LENGTH SHALL BE 1/8"
(MIN.) TO 1" (MAX.) SHORTER
THAN JOIST SPACE.
- 3) SPACE BLOCKS @ 12'o.c. (MAX.),
AND EA. END OF JOIST RUN.
- 4) USE (4) # 10-16 SCREWS AS
SHOWN AT JOIST LAP.

ClarkDietrich BUILDING SYSTEMS
A683 WITH (2) SCREWS AS REQUIRED,
TO JOIST AND (1) FASTENER PER TABLE
T.1 TO BEARING SUPPORT

F1200 JOIST LAP - STANDARD
ClarkDietrich TradeReady Floor Joist System